

ENERGY AUDIT - 2023



SREE SANKARA COLLEGE KALADY, ERNAKULAM

EXECUTED BY



ATHUL ENERGY CONSULTANTS PVT LTD

4th FLOOR, CAPITAL LEGEND BUILDING,
KORAPPATH LANE, ROUND NORTH, THRISSUR-680020
Ph: +91 7356111990-6 Web: www.athulenergy.com E-Mail: info@athulenergy.com

May 2023



TABLE OF CONTENTS

PREFACE	5
ACKNOWLEDGEMENTS.....	6
EXECUTIVE SUMMARY	7
1. ENERGY SAVING PROPOSALS.....	7
2. ENERGY AUDIT SUMMARY & RECOMMENDATIONS.....	7
3. ENERGY PERFORMANCE INDEX (EPI)	9
4. ANNUAL CARBON FOOTPRINT OF APPLIANCES	10
5. CARBON FOOT PRINT	11
INTRODUCTION.....	12
1. ENERGY AUDIT	12
2. SREE SANKARA COLLEGE, KALADY.....	13
3. GENERAL DETAILS.....	14
4. LOAD BALANCE- ELECTRICAL	15
ENERGY & UTILITY DESCRIPTION	16
1. SINGLE LINE DIAGRAM – ELECTRICAL.....	16
2. SINGLE LINE DIAGRAM – WATER.....	17
ENERGY ANALYSIS.....	18
1. ELECTRICITY CONSUMPTION ANALYSIS	18
I. DESCRIPTION OF ELECTRICITY BILL.....	18
II. DEMAND ANALYSIS.....	19
III. ELECTRICITY DEMAND IN VARIOUS TIME ZONES.....	20
IV. POWER FACTOR ANALYSIS IN KSEBL BILL	21
V. TARIFF RATES ANALYSIS.....	22
VI. SPECIFIC ELECTRICITY CONSUMPTION (KWH/STUDENTS & STAFF & KWH/BUILDING AREA)	23
2. DIESEL CONSUMPTION ANALYSIS.....	24
3. LPG CONSUMPTION ANALYSIS.....	25
ANNEXURE – 1	26
1. ENERGY SAVING PROPOSALS - 1.....	26
2. ENERGY SAVING PROPOSALS - 2.....	27
3. ENERGY SAVING PROPOSALS – 2.....	28
4. ENERGY SAVING PROPOSALS – 4.....	29
5. ENERGY SAVING PROPOSAL – 5	30



RENEWABLE ENERGY INTEGRATION	31
1. GENERAL REQUIREMENT FOR ROOF TOP SOLAR PV PLANT INSTALLATION.....	31
2. CALCULATION	32
ANNEXURE-2	33
1. CONNECTED ELECTRICAL LOADS.....	33
ANNEXURE-3	37
1. LIST OF INSTRUMENTS	37
2. ABBREVIATIONS.....	37
3. REFERENCES:.....	37
4. CERTIFICATES.....	38

LIST OF TABLES

TABLE 1: ENERGY SAVING PROPOSALS	7
TABLE 2: ENERGY PERFORMANCE INDEX.....	9
TABLE 3 CARBON FOOT PRINT.....	11
TABLE 4: GENERAL DETAILS	14
TABLE 5: CONNECTED LOAD	15
TABLE 6: KSEBL BILL ANALYSIS	18
TABLE 7: SPECIFIC ELECTRICITY CONSUMPTION	23
TABLE 8: DIESEL CONSUMPTION	24
TABLE 9: GENERATOR DETAILS.....	24
TABLE 10: LPG CONSUMPTION.....	25
TABLE 11 EC PROPOSAL NO:1.....	26
TABLE 12 EC PROPOSAL NO:2.....	27
TABLE 13 EC PROPOSAL NO:3.....	28
TABLE 14 EC PROPOSAL NO:4.....	29
TABLE 15 EC PROPOSAL NO:5.....	30
TABLE 16 RENEWABLE ENERGY INTEGRATION.....	32
TABLE 17 LIGHT AND FAN LOADS	33
TABLE 18 OTHER LOADS.....	34
TABLE 19 LAB EQUIPMENTS.....	35
TABLE 20 AIR CONDITIONER LOADS.....	36

LIST OF FIGURES



FIGURE 1: ANNUAL CO ₂ EMISSION.....	10
FIGURE 2: CARBON FOOT PRINT.....	11
FIGURE 3: LOAD BALANCE – ELECTRICAL.....	15
FIGURE 4: SINGLE LINE DIAGRAM – ELECTRICAL.....	16
FIGURE 5: SINGLE LINE DIAGRAM - WATER.....	17
FIGURE 6: DEMAND IN VARIOUS TIME ZONE.....	19
FIGURE 7: ELECTRICITY DEMAND IN VARIOUS TIME ZONE.....	20
FIGURE 8: POWER FACTOR ANALYSIS.....	21
FIGURE 9: TARIFF RATE ANALYSIS	22
FIGURE 10: SPECIFIC ELECTRICITY CONSUMPTION	24



PREFACE

Every institution should be imparting knowledge about the campus environment and its surroundings through activities that follows the principles of sustainability. An energy audit is essential first step to reduce energy cost and greenhouse emissions. Audit is defined as a systematic and implement examination of data statements, records, operations and performance of an enterprise for a purpose. Energy audits is a systematic study or survey to identify how energy being used in its own facility. And identifying the energy savings opportunities in the building Behavioural Change through the student education can provide greatest benefit at least cost. Even small savings in each house holds make dramatic change in the society and for nation. The idea of energy conservation and sustainability will be percolated to society through students will have long standing effect and successful too.

This report is compiled by the BEE certified energy auditor along with the project engineers who are experienced in the field of energy, environment and management.

ACKNOWLEDGEMENTS

We express our sincere gratitude to Sree Sankara College, Kalady for giving us an opportunity to carry out the project of Energy Audit. We are extremely thankful to all the staffs for their support to carry out the studies and for input data, and measurements related to the project of Energy Audit.

- | | | |
|---|------------------|-------------------|
| 1 | Dr. Preethi Nair | Principal |
| 2 | Dr. Manju T | IQAC Co-ordinator |

Also mentioning our Energy audit team members for successfully completing the assignment in time and making their best efforts to add value.

ENERGY AUDIT TEAM

1. **Mr. Santhosh A**
Registered Energy Auditor of Bureau of Energy Efficiency (BEE – Govt. of India)
Accredited Energy Auditor No – EA 7597
2. **Mr. Ashok K M P**
Registered Energy Manager of Bureau of Energy Efficiency (BEE – Govt. of India)
Accredited Energy Manager No – EA 25612
3. **Mr. Harikrishnan K**
Project engineer
4. **Ms. Keerthana K**
Project engineer
5. **Ms. Neema Joy P**
Project engineer

Yours faithfully

Managing Director
Athul Energy Consultants Pvt Ltd



EXECUTIVE SUMMARY

1. ENERGY SAVING PROPOSALS

TABLE 1: ENERGY SAVING PROPOSALS

Sl. no	Energy conservation measures	Annual Energy Savings	Annual Financial Savings	Investment	Simple payback period
		kWh	Rs	Rs	Months
1	Power factor Improvement from 0.97 to 0.99		23,025	16,000	8
2	Contract Demand optimization by improving the PF		16,345	Nil	Immediate
3	Replacement of Ceiling fans(75W) with BLDC fans 5 star rated(28W) – 250 nos	10,575	78,255	8,75,000	134
4	Replacement of Fluorescent lights T12(40W) -49 nos & T8 (36W) - 130 nos with LED (20W)	2,203	16,304	53,700	40
5	Replacement of non/low star AC (1.5 Ton) with 5-star AC (1 Ton)	1,337	9,894	38,000	46
Total		14,115	1,43,823	9,82,700	82
6	Integration of 50 kW Solar PV system		4,08,000	27,50,000	7 Years

2. ENERGY AUDIT SUMMARY & RECOMMENDATIONS

The summary of the report with respect to each section is as follows.

1. Baseline energy performance:

Electricity consumption analysis

- **Demand analysis:** The demand analysis was done for the last 12 months. It is found that the recorded maximum demand was 119 kVA which is 99.5% of the contract demand. The percentage of recorded maximum demand in the normal, Peak and off-peak period registered with respect to the contract demand (120 kVA) is 99.5%, 58.8%, and 43.5% respectively.
- **Power factor:** The PF in the last 12 months was found to be 0.97 (average). Installing 16kVar inline capacitor across the incomer (LT side) would help to maintain the power factor above the prescribed limit and improve the power factor to unity



- **Renewable energy integration:** College is benefitted with space in its roof top hence they can go for solar installations in their facility and go for zero billing and claimed as solar powered college or self-sustainable College.
- **Sub metering of panels:** Sub metering of panels suggested to know the separate energy consumption of each building.

2. Equipment and utility description

- **Light loads:** By replacing the fluorescent lighting fixtures (T12, T8) with LED light will reduce the overall power consumption. Detailed analysis given in the energy conservation measures section.
- **Ceiling fan loads:** Ceiling fans are installed in majority of the areas by replacing it with Brushless DC fans which consumes in the range of 25 to 30W at full speed, instead of 75W in normal fans, will reduce the power consumption considerably. Also, while purchasing new fans priority should be given for BLDC.

3. ENERGY PERFORMANCE INDEX (EPI)

EPI was based on the energy consumption in May 2022 to April 2023. The projected energy consumption after the implementation of energy saving proposals is given in the table below.

TABLE 2: ENERGY PERFORMANCE INDEX

Sl. No:	Energy Performance and climate impact	Unit	Baseline	Projection	% of reduction - annum
1	Annual Electricity Consumption*	kWh	1,92,610	1,78,495	7.33
		TOE	17	15	
2	Annual Diesel Consumption	kg	830	830	0.00
		TOE	0.8	0.8	
3	Annual LPG Consumption	Kg	328	328	0.00
		TOE	0.344	0.344	
4	Total Energy Consumption	TOE	17.70	16.48	
5	Energy Performance Index	TOE/Sq.m	0.00093	0.00086	
6	Annual Energy Cost	Rs in lakhs	24.29	22.85	5.92
7	Annual Specific Electricity Consumption	kWh/Students & Staff	85	79	
		kWh/Sq.m	10.10	9.36	
8	Annual Specific Electricity Consumption	TOE/Students & Staff	0.008	0.007	
9	Annual Carbon Footprint- Electricity	Ton CO ₂	152	141	7.33
10	Annual Carbon Footprint- Diesel	Ton CO ₂	2.56	2.56	0.00
11	Annual Carbon Footprint- LPG	Ton CO ₂	0.98	0.98	0.00
12	Annual Specific Carbon Footprint	Ton CO ₂ /Student	0.069	0.064	7.16

* Only sixty percentage of the total electricity consumption is taken into consideration since the electric connection is common for all other institution in the campus premises.

Note: Unit conversions:

TOE	=	10 million kCal (BEE energy audit manual)
MWh of electricity	=	0.79 Ton of CO ₂ (www.cea.gov.in)
Kg of LPG	=	2.99 Ton of CO ₂ (www.cea.gov.in)
Kilogram of Diesel	=	3.085 Ton of CO ₂ (www.cea.gov.in)
Kg of LPG	=	10500 kCal (BEE energy audit manual)
Kilogram of Diesel	=	9500 kCal (BEE energy audit manual)
kWh of electricity	=	860 kCal (BEE energy audit manual)

4. ANNUAL CARBON FOOTPRINT OF APPLIANCES

The present carbon dioxide generation by appliances in the college and the projected value after the implementation of the energy conservation measures is given in the figure below




FIGURE 1: ANNUAL CO₂ EMISSION

5. CARBON FOOT PRINT


Carbon foot print is often used as short hand for the amount of carbon emission (usually in Tonnes) being emitted by an activity or by organization this is an important component in ecological foot print or the depicting the biological space reduction in the earth. Various environment protection and energy conservation connected with carbon footprint. Institution took its accountability to protect nature and taken few steps for the carbon neutral campus

1. Protecting and conserving trees inside and outside the campus through various students' activities
2. Replacement of old CFLs and tubes with energy efficient LED lights
3. Sustainable construction of buildings for natural ventilation and light in the classrooms and laboratories.

TABLE 3 CARBON FOOT PRINT

Particulars	Energy consumption reduction (kWh)	Carbon Emission reduction (Ton CO ₂)	% of total
Replacement of 281numbers of T8 Tube (36W) with LED tube light	3237	2.56	62
Replacement of 301 numbers of CFL (18 W) with (9W)LED	1950	1.54	38
Total	5187.6	4.10	100

FIGURE 2: CARBON FOOT PRINT



INTRODUCTION

1. ENERGY AUDIT

An energy audit is a key to assessing the energy performance of an energy consuming facility and for developing an energy management program. The typical steps of an energy audit are:

- Preparation and planning
- Data collection and review
- Plant surveys and system measurements
- Observation and review of operating practices
- Data documentation and analysis
- Reporting of the results and recommendations

1.1. Definition of energy auditing

In the Indian Energy Conservation Act of 2001 (**BEE 2008**), an energy audit is defined as: "**The verification, monitoring and analysis of the use of energy and submission of technical report containing recommendations for improving energy efficiency with cost-benefit analysis and an action plan to reduce energy consumption.**"

1.2. Objectives of Energy Auditing

The objectives of an energy audit can vary from one plant to another. However, an energy audit is usually conducted to understand how energy issued within the plant and to find opportunities for improvement and energy saving. Sometimes, energy audits are conducted to evaluate the effectiveness of an energy efficiency project or program. In the College as per the request from the institution, we have assessed the energy consumption and saving opportunities at present scenario.

Methodology for the study

The methodology adopted for energy audit starts from historical energy data analysis, power quality analysis, monitoring of operational practices, system evaluation, cost benefit analysis of the energy conservation opportunities, and prepare plan for implementation. The proposals given in the report includes economical energy efficiency measures to reduce facilities unnecessary energy consumption and cost. The energy conservation options, recommendations and cost benefit ratio, indicating payback period are included in this report.

Scope of Work

The Scope of Work includes:

1. Historical energy data analysis.
2. Electrical, Mechanical and Thermal energy analysis.
3. Power Quality Analysis.
4. Identification of Energy saving opportunities.
5. Cost Benefit Analysis.

2. SREE SANKARA COLLEGE, KALADY

Sree Sankara College, Kalady was founded in the year 1954 by Swami Agamananda, a social reformer and a foresighted scholar of Sri Ramakrishna Advaita Ashram. The institution was established with a view to perpetuating the memory and doctrines of the great saint and philosopher, Adi Sankaracharya and to nurture his birth place as a cultural citadel. The foundation stone was laid on 28 August, 1953 by His Highness the Maharaja of Travancore in the presence of The Maharaja of Cochin and several other distinguished personalities. The Sree Sankara College Association was formed in July 1953.

The vision & mission of the organization was to establish a Centre of Higher Learning with two major objectives —dissemination of knowledge in tune with a university curriculum and fostering community development.

The institution was raised to the status of a First Grade College in 1956. It is affiliated to the Mahatma Gandhi University and is included under sec.2 (f) and 12 (B) of the UGC act, 1956.

In June 1960, the patronage of the college became vested in His Holiness the Jagadguru Sri Sri Sankaracharya Swamigal of Dakshinamnaya. Currently, Sri Sri Bharathi Theertha Mahaswamigal, of Sringeri Mutt, steers the administration through a Board of Directors with Sri. K. Anand as the Managing Director.

The college has done consistently well in Curricular and Cocurricular activities. The National Assessment and Accreditation Council (NAAC), a statutory body of the UGC has accredited the college B Grade with 2.82 CGPA on a four-point scale. The Departments of Economics, Commerce, Sanskrit and Microbiology are approved Research Centres under the Mahatma Gandhi University.

VISION

To achieve excellence in higher Education, with a stress on, creativity, skill development, employability, personal values with social

MISSION

To mould good citizens with ingenuity, adaptability, social commitment and ethical values who can provide innovative leadership in all walks of life.

3. GENERAL DETAILS

The general details of the College are given below in table.

TABLE 4: GENERAL DETAILS

Sl. No:	Particulars	Details
1	Name of the College	Sree Sankara College, Kalady
2	Address	Sree Sankara College Sankar Nagar, Mattoor, Kalady P.O., Ernakulam – 683 574
3	Contact Person	Dr. Mini K D, Ph: 9605055445
4	Contact Number & E mail	0484-2462341
		info@ssc.edu.in
5	Web site	www.ssc.edu.in
6	Type of Building	Educational Institution
7	Annual Working Days	180
8	No: of Shifts	Day Shift (One) (9:30AM -3:30PM)
9	No: of students enrolled	2100
10	No: of teaching staff	100
11	No: of non-teaching staff	44
12	No: of departments	20
13	Total Built Up area	19078 Sq. m
14	Total land area	18 acres
15	Average power consumption per month.	26,751 kWh
16	Average electricity charges per month.	Rs. 2,64,088 /-

4. LOAD BALANCE- ELECTRICAL

The details of the loads installed in the college are given below:

TABLE 5: CONNECTED LOAD

Sl. No:	Particulars	Total Load (kW)	Percentage
1	Light & Fan	76.90	34
2	Computer and other electronic loads	55.46	25
3	Air Conditioner Load	29.60	13
4	Other Loads	62.66	28
Total Power (kW)		224.61	100




FIGURE 3: LOAD BALANCE – ELECTRICAL

ENERGY & UTILITY DESCRIPTION

In this section the single line diagrams of electricity and water are given which provides an overview of the energy flow in the building.

1. SINGLE LINE DIAGRAM - ELECTRICAL

The electrical single line diagram of the college is given below:




FIGURE 4: SINGLE LINE DIAGRAM - ELECTRICAL

2. SINGLE LINE DIAGRAM - WATER




FIGURE 5: SINGLE LINE DIAGRAM - WATER

ENERGY ANALYSIS

The different type's energy usage is given in this section. The major source of energy to the college is electricity. Other forms come in the form of diesel and LPG.

1. ELECTRICITY CONSUMPTION ANALYSIS

The major source of electricity to the college and hostel is the electrical connection from the KSEBL. Three diesel generators are provided in the college, but it is only used during the power failures in critical days like examinations or college events.

I. DESCRIPTION OF ELECTRICITY BILL

Base line data given below is based on the Electricity bill provided by the supplier of electricity to the College. Details obtained from the KSEBL bill for the month of May 2022 to April 2023 is as follows in the Table.

TABLE 6: KSEBL BILL ANALYSIS


Particulars	Details	
Consumer No	LCN: 4/9247	
Contract Demand (kVA)	120 kVA	
Connected Load (kW)	288.476 kW	
Tariff	HT II (B) General	
Recorded maximum demand (kVA)	119.44	
Average monthly electricity consumption (kWh/month)	26,751	
Average Power factor	0.97	
Average Demand charges (Rs/month)	53,289	
Annual power factor penalty & Incentive (Rs/year)	Penalty – Rs. 2,014 /- Incentives – Rs.21,166 /-	
Demand charge (Rs / kVA)	440	
Revised Demand Charge from June 2022	500	
Energy charge (Rs/kWh)	Normal	6.2
	Peak	9.3
	Off Peak	4.65
Revised Energy charge (Rs/kWh) from June 2022	Normal	6.8
	Peak	10.2
	Off Peak	5.1
Average electricity cost (Rs/month)	2,64,088/-	

**Inference & Suggestions**

- Average Power factor is found to be 0.97. The college received incentives for 10 out of 12 months due to their power factor being above the prescribed limit of 0.95. However, they were levied a penalty for one month during which the power factor was below the prescribed limit.
- 16kVAr inline capacitor can be connected at the transformer secondary side to improve the PF to unity. Detailed explanation provided in the annexure-1
- Recorded maximum demand (RMD) during past 12 month was 119.44 kVA. It was recorded during the month of February 2023.

II. DEMAND ANALYSIS

This section analyses the trend for the maximum demand versus the Contract Demand (CD) over a 12-month period (May 2022 to April 2023).

**FIGURE 6: DEMAND IN VARIOUS TIME ZONE****Inference**

- Annual demand charges came as **Rs. 6,39,467 /-**
- The recorded maximum demand came in the range of 65.2% to 99.5% with respect to the contract demand with an average of 89.9%.
- The recorded maximum demand was observed to be above the minimum demand that is being charged by the utility which is 90 kVA in every month except for May 2022.

**Suggestion**

- i. Maintaining the power factor to near unity in lagging mode yields dual benefits, the demand will further reduce and the incentives for the power factor will rise.
- ii. Installing capacitor will help to maintain the power factor to near unity.

III. ELECTRICITY DEMAND IN VARIOUS TIME ZONES

The variations of demands in the time zones are given below in figure.




FIGURE 7: ELECTRICITY DEMAND IN VARIOUS TIME ZONE

Inference

- i. The average demand registered during the normal, Peak and off-peak period at college with respect to the contract demand (120 kVA) were 89.9%, 44% and 37.1% respectively.
- ii. The percentage of maximum demand during the normal, Peak and off-peak period registered at institution with respect to the Contract demand (120 kVA) were 99.5%, 58.8% and 43.5% respectively.

IV. POWER FACTOR ANALYSIS IN KSEBL BILL

The Power factor is the ratio of Active power (kW) and apparent power (kVA).

$$PF = \text{Active energy kWh} / \text{Apparent energy (kVAh)}$$

The power factor variations in past one year is given below in figure.




FIGURE 8: POWER FACTOR ANALYSIS

Inference

- Average power factor during the past one year is found to be 0.97
- Power factor penalty was paid by college for September 2022. If the power factor is maintained close to unity, penalty incurred can be avoided.
- Capacitors are not installed. A 16 kVAr inline capacitor can be provided at the transformer secondary so as to improve the PF and gain incentives. Detailed explanation is given in the section Energy Conservation Measures ECM 01.



V. TARIFF RATES ANALYSIS

The average monthly energy and demand charges for the period May 2022 to April 2023 is represented in Fig.




FIGURE 9: TARIFF RATE ANALYSIS

Inference

- i. Average demand charges for the past one year were **Rs 53,289 /-** per month and energy charges was **Rs 1,91,875 /-** per month.
- ii. The energy charges come about 73% of the total bill.

VI. SPECIFIC ELECTRICITY CONSUMPTION (KWH/STUDENTS & STAFF & KWH/BUILDING AREA)


The electricity consumption from the May 2022 to April 2023 has been taken for the benchmarking. Here the comparison is done with electricity consumption and the building area and number of students. The below table shows the specific electricity consumption of the college.

TABLE 7: SPECIFIC ELECTRICITY CONSUMPTION

Month	Unit Consumption*	No: of students & Staff	Building area	Specific Electricity Consumption	SEC
	kWh	Number	m ²	kWh/Students & Staff	kWh/m ²
May-22	14268	2263	19,078	6.30	0.75
Jun-22	18313	2263	19,078	8.09	0.96
Jul-22	14954	2263	19,078	6.61	0.78
Aug-22	15938	2263	19,078	7.04	0.84
Sep-22	11986	2263	19,078	5.30	0.63
Oct-22	15331	2263	19,078	6.77	0.80
Nov-22	18446	2263	19,078	8.15	0.97
Dec-22	15390	2263	19,078	6.80	0.81
Jan-23	18546	2263	19,078	8.20	0.97
Feb-23	17339	2263	19,078	7.66	0.91
Mar-23	19355	2263	19,078	8.55	1.01
Apr-23	12743	2263	19,078	5.63	0.67
Average	16051	2263	19078	7.09	0.84
Annual Specific Electricity Consumption				85.11	10.10
Annual Energy Consumption*					1,92,610

* Only sixty percentage of the total electricity consumption is taken into consideration since the electricity connection is common for all other institution in the campus premises.

The energy performance index is plotted in the below chart which gives a pictorial representation of the specific electricity consumption and units consumed in various months during the period from May 2022 to April 2023.



**FIGURE 10: SPECIFIC ELECTRICITY CONSUMPTION**

2. DIESEL CONSUMPTION ANALYSIS

The Diesel is the fuel which is used for the DGs. The details of the diesel consumption in the last academic year and the generator details are given in the table below.

TABLE 8: DIESEL CONSUMPTION

Particulars	Annual Diesel consumption (kg)	Calorific value (TOE)
Generator	830	0.79

Calorific value of Diesel is 9500 Kcal and 1 TOE means 10000000 Kcal.

TABLE 9: GENERATOR DETAILS

Particulars	Make	kVA	Fuel
New Building	-	25	Diesel
Microbiology Block	Kirloskar	25	Diesel
Main Block	KOEL	62.5	Diesel



3. LPG CONSUMPTION ANALYSIS

The details of the LPG consumption in the last academic year are given in the table below.

TABLE 10: LPG CONSUMPTION

Particulars	Annual LPG consumption (Kg)	Calorific value (TOE)
Microbiology Lab	193	0.20
Biotechnology Lab	77.2	0.08
Biochemistry Lab	19.3	0.02
Zoology Lab	38.6	0.04
Total	328	0.34

ANNEXURE – 1

1. ENERGY SAVING PROPOSALS - 1

PF IMPROVEMENT IN ELECTRICAL SYSTEM

Background

By referring the last year bills, it is clear that the power factor was below the prescribed limit for several months. As per the KSEBL tariff structure, if the PF is maintained above 0.95(lag), the consumer is entitled to receive incentives.

Proposal

- Provide inline capacitor of 16kVAr at the transformer secondary side to improve the PF to unity and gain incentives.

Calculations for the energy saving proposal is given in the table below.

Table 11 EC PROPOSAL NO:1

Particulars	Units	Values
Present PF		0.97
Proposed PF		0.99
Present average energy consumption/month	kWh/month	26,751
Present average energy charge/month	Rs/month	1,91,875
Incentives for improving the PF/month	Rs/month	1,919
Annual incentive	Rs/annum	23,025
Annual Savings	Rs/annum	23,025
Investment @Rs.1000 per kVAr	Rs	16,000
Payback period	Months	8

2. ENERGY SAVING PROPOSALS - 2

CONTRACT DEMAND OPTIMIZATION BY IMPROVING THE PF

Background

The contract demand of the College is found to be 120 kVA. By analysing the past 12 months bills, it is found that the maximum demand registered in the college was 119.44 kVA which is about 99.5% of the contract demand. The power factor in the college is found to be low with an average value of 0.97 lagging. Also, the average demand registered during the past 12 months was 68.42 kVA which is 57% of contract demand.

Proposal

It is proposed to improve the power factor to unity by providing an inline capacitor of 16 kVAr at the transformer secondary. By implementing EC Proposal 01, the demand on the college will come down considerably and the demand charges also reduces. The average maximum demand will reduce from 108 kVA to 105 kVA thus resulting in a 3% reduction in the demand. Detailed calculation for the proposal is shown in the table below.

Calculations

Table 12 EC PROPOSAL NO:2

Particulars	Units	Value
Present average registered maximum demand	kVA	108
Present average registered power factor		0.97
Proposed Power factor		0.99
Expected average maximum demand/month	kVA	105
Reduction in demand - average/month	kVA	3
Demand charges	Rs/kVA	500
Savings in demand charges/month	Rs/Month	1362
Annual financial savings in demand charges	Rs/Year	16,345
Investment cost	Rs	Nil
Simple payback period	Months	Immediate

3. ENERGY SAVING PROPOSALS - 2

REPLACEMENT OF CEILING FANS IN THE OFFICE WITH ENERGY EFFICIENT BLDC FANS

BACKGROUND

A BLDC fan takes in AC voltage and internally converts it into DC using SMPS. The main difference between BLDC and ordinary DC fans is the commutation method. A commutation is basically the technique of changing the direction of current in the motor for the rotational movement. In a BLDC motor, as there are no brushes, so the commutation is done by the driving algorithm in the Electronics. The main advantage is that over a period, due to mechanical contact in a brushed motor the commutators can undergo wear and tear, this thing is eliminated in BLDC Motor making the motor more rugged for long-term use. To explain, BLDC technology in simpler terms, BLDC uses a combination of Permanent Magnets and Electronics to achieve the kind of efficiency and performance, it delivers. A BLDC fan composes of 3 main components: - 1. Stator 2. Rotor 3. Electronics

PROPOSAL

Replace the ceiling fans with BLDC in the as per preference of operating hours as office areas. Staff rooms and in class rooms and in hostels the calculation for the savings is given in the table.

Table 13 EC PROPOSAL NO:3

Particulars	Units	BLDC fan
Present Power Consumption	Watts	75
Proposed Power Consumption	Watts	28
Reduction in power	Watts	47
Operating hours per day	Hr/day	5
No: of working days per year (Average)	Nos	180
No: of fans operating	Nos	250
Annual energy savings	kWh/year	10575
Cost per kWh	Rs	7.40
Annual Financial Saving	Rs/year	78255
Cost of BLDC fan	Rs	3500
Investment	Rs	875000
pay back	Month	134

4. ENERGY SAVING PROPOSALS – 4

REPLACEMENT OF FLUORESCENT TUBES WITH ENERGY EFFICIENT LED LIGHTS

BACKGROUND

The present light fittings are mainly been the LED and fluorescent light of different ratings. Replacement of Fluorescent lights to be done in phase manner with LED lights.

PROPOSAL

By replacing the light fitting with LEDs of appropriate ratings the power consumption will reduce considerably by approximate 50% with the present operating hours. The calculation for the savings, approximate investment cost and payback period is given in the table below.

Table 14 EC PROPOSAL NO:4

Particulars	Units	T8	T12
Power of Fluorescent lights	Watts	40	36
Power of proposed LED tube	Watts	20	20
Difference in Wattage	Watts	20	16
Operating hours per day	Hrs/day	4	4
No: of working days per year (Average)	Nos	180	180
Number of Lights operating	Nos	49	130
kWh Saving per Annum	kWh/year	706	1498
Cost per kWh (Average)	Rs	7.40	7.40
Annual Financial Savings	Rs/year	5221	11082
Cost of LED tube	Rs	300	300
Investment for LED lights	Rs	14700	39000
Simple Payback period	Months	34	42
SUMMARY			
Annual unit savings	kWh	2203	
Total savings	Rs	16304	
Total investment	Rs	53700	
Payback period	months	40	

5. ENERGY SAVING PROPOSAL – 5

REPLACEMENT OF 3 STAR AC WITH ENERGY EFFICIENT 5 STAR AC

BACKGROUND

The present Air conditioners in the server room are having high power consumption as they having low star AC. This is the sample calculation for replacement of AC at PG block server room (Room No: T38) the operating hours are 24 Hrs. and with low star value.

PROPOSAL

Replace the 1.5 TR 3-star with new 1 ton 5 star rated one will provide sufficient energy savings. The calculation for savings is given in the tables below.

Table 15 EC PROPOSAL NO:5

Particulars	Units	Value
Present power consumption of AC	Watts	1334
Power of proposed 5 Star AC	Watts	715
Difference in Wattage	Watts	619
Avg No: of working hours/day	Hrs/day	12
No: of working days per year (Average)	Nos/year	180
No: of working hours per annum	Hrs/year	2160
Number of AC operating	Nos	1
kWh Saving per Annum	kWh/year	1337
Cost per kWh (Average)	Rs	7.4
Annual Financial Savings	Rs/year	9894
Cost of 5 Star AC	Rs	38000
Investment for AC	Rs	38000
Simple Payback period	Months	46

RENEWABLE ENERGY INTEGRATION

The Sun is an inexhaustible, reliable and non-polluting source of power. Since the inception of life on earth, the only energy that was available came from the sun. The time is now approaching when humankind will again depend upon the sun as dominant energy source. We are aware that fossil fuels are not going to last forever. Of the numerous renewable sources of energy known to mankind, Solar Photo Voltaic or SPV is one that has the potential to supply power for our future needs. The advantages of solar power are:

- 1) The solar energy is more evenly distributed in the world than wind or biomass.
- 2) It is well proven and demonstrated technology.
- 3) It promises to be most cost-effective renewable power at high volumes.

1. GENERAL REQUIREMENT FOR ROOF TOP SOLAR PV PLANT INSTALLATION

SPACE REQUIREMENT FOR PANEL MOUNTING:

A minimum shadow free space of 10 m² is required for the solar panel mounting for the capacity of 1KW. The panel must be mounted facing south with appropriate inclination for maximum output from installation. Suitable structure according to wind speed and roof structure must be used without shading the panel surface.

SOLAR PV MODULES AND INVERTER:

Solar PV panels of 300W or above must be selected for the rooftop installation above 10KW. The efficiency of individual panel must not be less than 16%.

String inverter with MPPT charge controllers is more suitable for the solar power plant installation in roof top. Equipment and installation must be complied with CEA grid regulations-2013.

LOCATION:

Open terrace on roof top is available in the indoor stadium 1323 m² approximately.



2. CALCULATION

The area available for solar installation is 1323 m² in the Roof top area at indoor stadium. On grid system of 50 kW can be installed in this location without any shades.

Table 16 RENEWABLE ENERGY INTEGRATION

Particular	Units	Value
Proposed system	kW	50
Approximate available units for utilization	kWh/day	200
Approximate annual unit generation	kWh /year	60,000
Present annual unit consumption*	kWh /year	1,93,568
Average utility electricity cost*	Rs	6.8
Annual Financial Savings	Rs/Annum	4,08,000
Investment (subsidized & in grid tied mode)	Rs	27,50,000
Simple payback period	Years	7

* Power consumption (kWh) and average utility cost (Rs. /kWh) is considered for normal period only

ANNEXURE-2

1. CONNECTED ELECTRICAL LOADS

i. LIGHT & FAN LOADS

Table 17 LIGHT AND FAN LOADS

Particular	T12	T8	LED Tube Light	LED	CFL	LED Spot Light	Sodium Vapour lamp	Mercury Vapour Lamp	Ceiling Fan	Pedestal Fan	Wall Fan	Exhaust Fan	Exhaust Fan
Block/Watts	40	36	20	9	18	40	50	60	75	60	60	80	120
Commerce Block	14	22	39	2					56	1			
Computer Block	3	3	15						5				
Microbiology Block	45	7	28	1	6				34			6	
Ladies Hostel		12	25	31			1		34			1	
Canteen			55	4					42			3	
New Block		219	15	58					130	3			
S - Block	12	16	16	22					53				
Common Toilet (Girls Toilet)	5	3	6	7								1	
Stadium		23									16		
Auditorium		8		72					25				
Main Block	103	124	82	104	7	1	1	1	181	1	7	4	2
Total Number	182	437	281	301	13	1	2	1	560	5	23	15	2
Total Watts	7280	15732	5620	2709	234	40	100	60	42000	300	1380	1200	240
Net Total Watts	7690												

ii. OTHER LOADS

Table 18 OTHER LOADS

Particular	PC	Printer	Projector	Amp lifier	Water Filter	Water Dispenser	Xerox	Printer 3 in 1	Scanner	Kettle	Coffee Maker	Incinerator	Vending M/C	TV	Induction Cooker	Motor	Motor
Block/Watts	200	120	150	250	120	920	750	400	80	1500	750	250	40	120	2000	1119	2237
Commerce Block	4	32	2			1						1					
Computer Block	16		1					1									
Microbiology Block	16	1	2														
Ladies Hostel					1									1	1		
Canteen	1		1		1						1						
New Block	4	2	7			4	1	1		2							
S - Block	3	2	2			1		1		1		1					
Common Toilet (Girls Toilet)												1	1				
Stadium																	
Auditorium																	
Main Block	42	11	8	1	2	1	7		2	2							
Others																1	1
Total Number	86	48	23	1	4	7	8	3	2	5	1	3	1	1	1	1	1
Total Watts	17200	5760	3450	250	480	6440	6000	1200	160	7500	750	750	40	120	2000	1119	2237
Total Watts	55456																

iii. LAB EQUIPMENT

Table 19 LAB EQUIPMENTS

Particular	Block/Watts	Microbiology Block	Canteen	New Block	Main Block
Centrifuge	350	2			
Water bath	200	3			
Water Bath	500	2		1	
Water Bath	2000			1	
Water Bath	1200			1	
Distillation Unit	350	1		2	
Distillation Unit	2500			1	
Hot Air Oven	2000	1			
Hot Air Oven	1000	1		3	2
Hot Air Oven	1500			2	
Freezer	800	2	3		
Incubator	2000	1			
Hot Plate	200			1	
Incubator	1500	1		2	
Fridge	160	10		6	4
Colorimeter	20	2		6	
Weighing M/C	20	2			
Incubator	500	2		2	
Incubator	800	3			
Incubator	1200			1	
Centrifuge	1650	1			
Laminar Air Flow	400	4		3	
Microwave oven	1100	2		1	
Ice M/C	750	1			
Centrifuge	500	1		1	
Shaker	110	1		1	
Auto Clave	2000	3			
Auto Clave	3000			2	
Auto Clave	500			1	
Vaccum Oven	187				1
Total Watts		28640	2400	28790	2827
Net Total (W)		62657			

**iv. AIR CONDITIONER LOADS****Table 20 AIR CONDITIONER LOADS**

Block	Floor	Location	Make	Type	Capacity	EER	Star rating	Working condition	Rated power
					Tr				Watts
Commerce Block	First Floor	FF11	Voltas	Split	1.5	2.95	3	Good	1695
	Second Floor	SF19	Voltas	Split	1	3.15	3	Good	1015
			Voltas	Split	1	3.15	3	Good	1015
		SF15	Lloyd	Split	1.5	3.59	3	Good	1875
PG Block	First Floor	T37	Voltas	Split	1	3.16	3	Good	1013
		T38 Server Room	Godrej	Split	1.5	3.7	3	Good	1334
Microbiology Block	Ground Floor	M2	Voltas	Split	1.5	3.16	3	Good	1656
	First Floor	Research Lab Micro Biology	LG	Split	1.5	3.19	3	Good	1900
		M9	Godrej	Split	1	3.11	3	Good	1061
Main Block	First Floor	Seminar Hall	Voltas	Split	2		3	Good	2071
			Voltas	Split	2		3	Good	2071
			Voltas	Split	2		3	Good	2071
			Voltas	Split	2		3	Good	2071
			Voltas	Split	2		3	Good	2071
		T3, Research Lab	Haier	Split	1	3.11	3	Good	1076
Office Block	Ground Floor	Front Office	Godrej	Split	1.5		3	Good	1334
			Godrej	Split	1.5		3	Good	1334
		G1, Manager Office	Voltas	Split	1.5			Good	1695
		Principal Office	Bluestar	Split				Good	1250
Total (W)									29604.63

ANNEXURE-3

1. LIST OF INSTRUMENTS

SL.NO	EQUIPMENT DESCRIPTION	MAKE & MODEL
1	POWER ENERGY & HARMONIC ANALYZER	KRYKARD ALM 31

2. ABBREVIATIONS

AVG	:	Average
BEE	:	Bureau of energy efficiency
CO ₂	:	Carbon dioxide
KSEB	:	Kerala State Electricity Board.
DB	:	Distribution Board
EC	:	Energy Conservation
IEEE	:	The Institute of electrical and electronics engineers
IS	:	Indian Standard
kL	:	kilo Litre
KVA	:	kilo Volt Ampere
kVAh	:	kilo volt Ampere Hour
kVA _r	:	kilo volt ampere
kW	:	kilo Watts
kWh	:	kilo watt hour
LT	:	Low tension
MAX	:	Maximum
NSS	:	National Service Scheme
SLD	:	Single Line Diagram


3. REFERENCES:

- Handbook on energy audit and environment management by TERI.
- Bureau of Energy Efficiency (BEE) books for certification of Energy Auditors & Managers.



4. CERTIFICATES


I. BEE Accreditation Certificate



BUREAU OF ENERGY EFFICIENCY

Examination Registration No.: **EA- 7597**

Accreditation Registration No.: **AEA-0275**



Certificate of Accreditation

This is to certify that Mr./Ms. **Santhosh. A** having its trade/registered office at **Kerala** has been given accreditation as accredited energy auditor. The certificate shall be effective from **2nd** day of **November, 2017**.


The certificate is subject to the provisions of the Bureau of Energy Efficiency (Qualifications for Accredited Energy Auditors and Maintenance of their List) Regulations, 2010.

This certificate shall be valid until it is cancelled under regulation 9 of the Bureau of Energy Efficiency (Qualifications for Accredited Energy Auditors and Maintenance of their List) Regulations, 2010.

On cancellation, the certificate of accreditation shall be surrendered to the Bureau within fifteen days from the date of receipt of order of cancellation.

Your name has been entered at AEA No. **0275** in the register of list of accredited energy auditors. Your name shall be liable to be struck out on the grounds specified in regulation 8 of the Bureau of Energy Efficiency (Qualifications for Accredited Energy Auditors and Maintenance of their List) Regulations, 2010.

Given under the seal of the Bureau of Energy Efficiency, Ministry of Power, this **12th** day of **February, 2018**


Secretary,
Bureau of Energy Efficiency
New Delhi



II. EMC Empanelment certificate



Energy Management Centre - Kerala (Department of Power, Govt of Kerala)

CERTIFICATE OF EMPANELMENT

This is to certify that **M/s.Athul Energy Consultants Pvt Ltd**(4/2, Capital Legend Building, Korapath Lane, Rouund North, Thrissur)is empanelled as Energy Audit firm in Energy Management Centre Kerala to conduct mandatory energy audit as per Government of Kerala G.O (Rt) No.2/2011/PD dated 01.01.2011.

Empanelment No:
EMCEEA-0811F-3

Scope/Area	Building	Industry -Electrical	Industry Thermal
	Yes	Yes	Yes

This empanelment is valid up to 01/02/2024

Issuing Date: 02/02/2021

Place: Thiruvananthapuram

Director,
Energy Management Centre - Kerala